



INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
18309-70-2075
State Number
24950

EQUIPMENT INSPECTED

| | | |
|-----------------------------------|--|------------------------|
| State Number: 24950 | Type of Unit: Passenger | Floor to Floor: 1 to 3 |
| Capacity: 3500 | Manuf: THYSSEN KRUPP | Speed: 125 |
| Landings: 2 | Installed: 06/19/2007 | Rope Size: 0 |
| Volts: 480 | Complied: | Entrances: 1 |
| OWNER | OCCUPANT | |
| CITY OF CHARLOTTE CATS FACILITIES | CATS SOUTH BOULEVARD LIGHT RAIL FACILITY | |
| 600 E. 4TH ST | 3200 S. BLVD | |
| CHARLOTTE, NC, 28202 | CHARLOTE, NC, 28217 | |

INSPECTION INFORMATION

| | | | | | |
|-------------------------------|----------------------------|---------------------------------|---------------------------|-----------------------|------|
| Inspection Date 11/05/2018 | Type Inspection Routine | Certificate Status Re-issued | Inspector 70 - Darnley | County MECKLENBURG | 60 F |
|-------------------------------|----------------------------|---------------------------------|---------------------------|-----------------------|------|

VIOLATIONS

5.1.21.1 Place the car alarm bell in working order. Minimum level of 80 dBA.

Items must be corrected by: 01/04/2019

Elevator Name: ELEVATOR # 1

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: John Pierson 704-432-3689

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

CITY OF CHARLOTTE CATS FACILITIES
600 E. 4TH ST
CHARLOTTE, NC, 28202