



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
18346-73-3347
State Number
23700

EQUIPMENT INSPECTED

State Number: 23700	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 2100	Manuf: THYSSEN KRUPP	Speed: 125
Landings: 1	Installed: 06/22/2006	Rope Size: 0
Volts: 480	Complied: 06/22/2006	Entrances: 1
OWNER	OCCUPANT	
ELON UNIVERSITY	KOURY BUISNESS CENTERMARTHA,SPENCER,LOVE	
803 HAGGARD AVENUE	401 N O'KELLY AVE	
ELON, NC, 27244	ELON, NC, 27244	

INSPECTION INFORMATION

Inspection Date 12/12/2018	Type Inspection Routine	Certificate Status Re-issued	Inspector 73 - James	County ALAMANCE
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------

1

VIOLATIONS

8.6.4.7 Clean the pit and the pit equipment.

Items must be corrected by: 02/10/2019

Elevator Name: MARTHA-SPENCER-LOVE

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Jaime Davis TKE

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ELON UNIVERSITY
803 HAGGARD AVENUE
ELON, NC, 27244