N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
18347-73-2860
State Number
27613

EQUIPMENT INSPECTED

State Number: **27613**
Capacity: 2100
Landings: 3
Volts: 208

Type of Unit: Passenger
Manuf: TKE
Installed: 08/05/2011
Complied:

Floor to Floor: 1 to 3
Speed: 100
Rope Size:
Entrances: 1

OWNER
ELON UNIVERSITY
100 CAMPUS DRIVE CB 2060
ELON, NC, 27244

OCCUPANT
COLONNADES - HARPER HALL (E)
525 E PHOENIX DRIVE
ELON, NC, 27244

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County
12/12/2018	Routine	Re-issued	73 - James	ALAMANCE

1

VIOLATIONS

8.6.5.14.1 Provide the annual relief valve and hydraulic system pressure test.

Items must be corrected by: 02/11/2019

Elevator Name: HARPER HALL (E)

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: Jaime Davis TKE

Inspector _____

THIS IS NOT AN INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:
ELON UNIVERSITY
100 CAMPUS DRIVE CB 2060
ELON, NC, 27244