



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**19079-70-5983**  
State Number  
**12580**

EQUIPMENT INSPECTED

State Number: <b>12580</b>	Type of Unit: Freight	Floor to Floor: 1 to 4
Capacity: 15000	Manuf: KONE	Speed: 150
Landings: 4	Installed: 07/29/1988	Rope Size: 5/8
Volts: 480	Complied: 08/18/1988	Entrances: 1
OWNER	OCCUPANT	
POST CONSUMER BRANDS	POST CONSUMER BRANDS	
2525 BANK ST	2525 BANK ST	
ASHEBORO, NC, 27203	ASHEBORO, NC, 27203	

INSPECTION INFORMATION

Inspection Date 03/20/2019	Type Inspection Compliance	Certificate Status Prev Issued	Inspector 70 - Darnley	County RANDOLPH
-------------------------------	-------------------------------	-----------------------------------	---------------------------	--------------------

76

VIOLATIONS

2.27.1.1.1 Place the in-car Emergency Phone in working order.

Items must be corrected by: 04/19/2019

Elevator Name: OAKMEAL BLDG

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Al Spencer & Terrence Franklin 336-683-5507

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

POST CONSUMER BRANDS  
2525 BANK ST  
ASHEBORO, NC, 27203