



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
19136-76-5648
State Number
26000

EQUIPMENT INSPECTED

State Number: 26000	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 2500	Manuf: TKE	Speed: 150
Landings: 3	Installed: 12/03/2008	Rope Size:
Volts: 480	Complied:	Entrances: 1

OWNER

PHOENIX RISING OF ASHE CO.
203 HAMPTON PLACE COURT
WEST JEFFERSON, NC, 28694

OCCUPANT

HOLIDAY INN EXPRESS
203 HAMPTON PLACE
W JEFFERSON, NC, 28694

INSPECTION INFORMATION

Inspection Date 05/16/2019	Type Inspection Routine	Certificate Status Re-issued	Inspector 76 - Crank	County ASHE
-------------------------------	----------------------------	---------------------------------	-------------------------	----------------

5

VIOLATIONS

8.6.4.8.2 Articles or materials not necessary for the maintenance or operation of the elevator shall not be stored in machinery spaces, machine rooms, control spaces and control rooms.

Items must be corrected by: 06/15/2019

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Holiday Inn 336-846-4000

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

PHOENIX RISING OF ASHE CO.
203 HAMPTON PLACE COURT
WEST JEFFERSON, NC, 28694