



INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
19269-87-5766
State Number
24950

EQUIPMENT INSPECTED

State Number: **24950** Type of Unit: Passenger Floor to Floor: 1 to 3
Capacity: 3500 Manuf: THYSSEN KRUPP Speed: 125
Landings: 2 Installed: 06/19/2007 Rope Size: 0
Volts: 480 Complied: Entrances: 1

OWNER OCCUPANT
CITY OF CHARLOTTE CATS FACILITIES CATS SOUTH BOULEVARD LIGHT RAIL FACILITY
600 E. 4TH ST 3200 S. BLVD
CHARLOTTE, NC, 28202 CHARLOTE, NC, 28217

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County	
09/26/2019	Routine	Re-issued	87 - Rankin	MECKLENBURG	60 F

VIOLATIONS

Elevator Name: ELEVATOR # 1

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainance with current codes.

Violations pointed out to: Gary R. Lee 704-432-5010 Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

CITY OF CHARLOTTE CATS FACILITIES
600 E. 4TH ST
CHARLOTTE, NC, 28202