



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
20156-57-3297
State Number
H2491

EQUIPMENT INSPECTED

State Number: H2491	Type of Unit: Hand Lift	Floor to Floor: 1 to 2
Capacity: 660	Manuf: SAVARIA	Speed: 13
Landings: 2	Installed: 09/17/2013	Rope Size:
Volts: 240	Complied:	Entrances: 2
OWNER	OCCUPANT	
ELKIN SCHOOLS	ELKIN HIGH SCHOOL	
202 W SPRING STREET	334 ELK SPUR STREET	
ELKIN, NC, 28621	ELKIN, NC, 28621	

INSPECTION INFORMATION

Inspection Date 06/04/2020	Type Inspection Routine	Certificate Status Re-issued	Inspector 57 - Evans	County SURRY
-------------------------------	----------------------------	---------------------------------	-------------------------	-----------------

86

VIOLATIONS

A18.1 Arms would not raise upon arriving at designated landings. Repair as necessary.

Items must be corrected by: 08/03/2020

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: ANTHONY SHROPSHIRE (336)835-3858

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ELKIN SCHOOLS
202 W SPRING STREET
ELKIN, NC, 28621