



INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
20295-69-2323
State Number
10065

EQUIPMENT INSPECTED

State Number: **10065** Type of Unit: Passenger Floor to Floor: M to 14
Capacity: 3500 Manuf: WESTINGHOUSE Speed: 450
Landings: 13 Installed: 03/05/1982 Rope Size: 5/8
Volts: 480 Complied: 04/29/1982 Entrances: 1

OWNER
SOUTH COLLEGE STREET LLC
201 S COLLEGE ST SUITE 2270
CHARLOTTE, NC, 28244

OCCUPANT
CHARLOTTE PLAZA
201 S. COLLEGE ST.
CHARLOTTE, NC, 28244

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County	
10/21/2020	Routine	Re-issued	69 - Fialo	MECKLENBURG	60 G

VIOLATIONS

8.6.4.9 Clean the oil from the car top.

Items must be corrected by: 12/20/2020

Elevator Name: ELEVATOR #2

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Larry.704-900-9792

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372
An invoice will be mailed to: SOUTH COLLEGE STREET LLC
201 S COLLEGE ST SUITE 2270
CHARLOTTE, NC, 28244