



INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
21267-87-4731
State Number
24950

EQUIPMENT INSPECTED

State Number: 24950	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 3500	Manuf: THYSSEN KRUPP	Speed: 125
Landings: 2	Installed: 06/19/2007	Rope Size: 0
Volts: 480	Complied:	Entrances: 1
OWNER	OCCUPANT	
CITY OF CHARLOTTE CATS FACILITIES	CATS SOUTH BOULEVARD LIGHT RAIL FACILITY	
600 E. 4TH ST	3200 S. BLVD	
CHARLOTTE, NC, 28202	CHARLOTE, NC, 28217	

INSPECTION INFORMATION

Inspection Date 09/24/2021	Type Inspection Not Inspected	Certificate Status Not Issued	Inspector 87 - Rankin	County MECKLENBURG	60 F
-------------------------------	----------------------------------	----------------------------------	--------------------------	-----------------------	------

VIOLATIONS

Cannot Inspect The Elevator, Last Years Inspection Fee Must Be Paid,

Elevator Name: ELEVATOR # 1

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Gary R. Lee 704-432-5010

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

CITY OF CHARLOTTE CATS FACILITIES
600 E. 4TH ST
CHARLOTTE, NC, 28202