N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
22320-107-0043
State Number
5938

EQUIPMENT INSPECTED

State Number: **5938**	Type of Unit: Passenger	Floor to Floor: 1 to 6
Capacity: 2000	Manuf: SCHINDLER	Speed: 300
Landings: 6	Installed: 03/27/1968	Rope Size: 1/2
Volts: 208	Complied: 04/08/1968	Entrances: 1

OWNER	OCCUPANT
FIRST EMPIRE TELEX	FIRST RALEIGH TELEX BLDG
C/O EMPIRE PROPERTIES	234 FAYETTEVILLE ST
RALEIGH, NC, 27601	RALEIGH, NC, 27601

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County	
11/16/2022	Routine	Re-issued	107 - Holder	WAKE	92 D

VIOLATIONS

8.6.4.7	Clean the pit and the pit equipment.
2.27.1.1.1	Place the in-car Emergency Phone in working order.can not hear operator
8.6.4.19.2 (b)	Provide the annual no load test.

Items must be corrected by: 11/26/2022

Elevator Name: ELEVATOR #2

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: david

Inspector _____

THIS IS NOT AN INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:
FIRST EMPIRE TELEX
C/O EMPIRE PROPERTIES
RALEIGH, NC, 27601