



INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
www.nclabor.com/elevator.htm  
919-707-7927

Report Number  
**25310-72-1538**  
State Number  
**5938**

EQUIPMENT INSPECTED

State Number: **5938**                      Type of Unit: Passenger                      Floor to Floor: 1 to 6  
Capacity: 2000                              Manuf: SCHINDLER                              Speed: 300  
Landings: 6                                      Installed: 03/27/1968                              Rope Size: 1/2  
Volts: 208                                        Complied: 04/08/1968                              Entrances: 1

OWNER    OCCUPANT  
FIRST EMPIRE TELEX                              FIRST RALEIGH TELEX BLDG  
C/O EMPIRE PROPERTIES                              234 FAYETTEVILLE ST  
RALEIGH, NC, 27601                              RALEIGH, NC, 27601

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County	
11/06/2025	Routine	Re-issued	72 - Mccloud	WAKE	92 D

VIOLATIONS

- 2.27.1.1.1                      Place the in-car Emergency Phone in working order.
- 8.6.4.7                              Clean the pit and the pit equipment.

Items must be corrected by: 01/05/2026

Elevator Name: ELEVATOR #2

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: dc elevator

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

FIRST EMPIRE TELEX  
C/O EMPIRE PROPERTIES  
RALEIGH, NC, 27601