



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
9111-48-387
State Number
25786

EQUIPMENT INSPECTED

State Number: **25786**

Capacity: 4000

Landings: 3

Volts: 480

Type of Unit: Passenger

Manuf: SCHINDLER

Installed: 08/06/2008

Complied: 08/06/2008

Floor to Floor: 1 to 3

Speed: 150

Rope Size:

Entrances: 2

OWNER

BRUNSWICK CO COURTHOUSE OPERATION SERVIC

P.O. BOX 249

BOLIVIA, NC, 28422

OCCUPANT

BRUNSWICK COUNTY ADMIN BLDG

30 GOVERNMENT CENTER DRIVE

BOLIVIA, NC, 28422

INSPECTION INFORMATION

Inspection Date
04/21/2009

Type Inspection
Routine

Certificate Status
Re-issued

Inspector
48 - Martin

County
BRUNSWICK

10

VIOLATIONS

n/a No violations found

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: JAMES

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

BRUNSWICK CO COURTHOUSE OPERATION SERVIC
P.O. BOX 249
BOLIVIA, NC, 28422