



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
9111-48-511
State Number
19289

EQUIPMENT INSPECTED

State Number: 19289	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2100	Manuf: THYSSEN KRUPP	Speed: 95
Landings: 2	Installed: 04/26/2000	Rope Size:
Volts: 460	Complied: 05/02/2000	Entrances: 1
OWNER	OCCUPANT	
BRUNSWICK COUNTY OPERATIONS SERVICES	SOUTHEASTERN MENTAL HEALTH	
P.O. BOX 249	45 COURTHOUSE DR.	
BOLIVIA, NC, 28422	BOLIVIA, NC, 28422	

INSPECTION INFORMATION

Inspection Date 04/21/2009	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

10

VIOLATIONS

n/a No violations found

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: JAMES

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

BRUNSWICK COUNTY OPERATIONS SERVICES
P.O. BOX 249
BOLIVIA, NC, 28422