



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
9124-48-073
State Number
23516

EQUIPMENT INSPECTED

State Number: 23516	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 2100	Manuf: OTIS	Speed: 100
Landings: 3	Installed: 02/22/2006	Rope Size: 0
Volts: 208	Complied: 02/22/2006	Entrances: 1
OWNER COMMUNITY AASSOCIATION MGMT. P.O. BOX 8126 OCEAN ISLE BEACH, NC, 28469	OCCUPANT VILLAS ON OSPREY RIDGE 174 CLUB HOUSE RD SUNSET BEACH, NC, 28468	

INSPECTION INFORMATION

Inspection Date 05/04/2009	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

10

VIOLATIONS

- 8.6.4.7.1 Clean the elevator pit.
8.6.4.15 Emergency operation of signaling devices, lighting, communication, and ventilation, shall be maintained. EMER. PHONE INOPERATIVE.

Items must be corrected by: 05/14/2009

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: UNAVAILABLE

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

COMMUNITY AASSOCIATION MGMT.
P.O. BOX 8126
OCEAN ISLE BEACH, NC, 28469