



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
9124-48-493
State Number
23519

EQUIPMENT INSPECTED

State Number: 23519	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 2100	Manuf: OTIS	Speed: 100
Landings: 3	Installed: 02/22/2006	Rope Size: 0
Volts: 208	Complied: 02/22/2006	Entrances: 1
OWNER		OCCUPANT
COMMUNITY ASSOCIATION MGMT.		VILLAS ON OSPREY RIDGE
P.O. BOX 8126		172 CLUB HOUSE RD
OCEAN ISLE BEACH, NC, 28469		SUNSET BEACH, NC, 28468

INSPECTION INFORMATION

Inspection Date 05/04/2009	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

10

VIOLATIONS

8.6.4.15 Emergency operation of signaling devices, lighting, communication, and ventilation, shall be maintained. EMER. PHONE INOPERATIVE.

Items must be corrected by: 05/14/2009

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: UNAVAILABLE

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

COMMUNITY ASSOCIATION MGMT.
P.O. BOX 8126
OCEAN ISLE BEACH, NC, 28469