



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
9126-24-493
State Number
10537

EQUIPMENT INSPECTED

State Number: 10537	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2100	Manuf: GENERAL	Speed: 100
Landings: 2	Installed: 06/15/1983	Rope Size:
Volts: 208	Complied: 07/05/1983	Entrances: 1
OWNER	OCCUPANT	
ASH CITY SCHOOLS	LUCY HERRING ADMIN BLDG	
PO BOX 7347	85 MOUNTAIN STREET	
ASHEVILLE, NC, 28802	ASHEVILLE, NC, 28801	

INSPECTION INFORMATION

Inspection Date 05/06/2009	Type Inspection Routine	Certificate Status Re-issued	Inspector 24 - Moore	County BUNCOMBE	11 B
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------	------

VIOLATIONS

8.6.1.6.5 Provide a tested up to date class ABC fire extinguisher in machinery space. Last date 4/08
8.6.1.2.1 Provide a written maintenance program.

Items must be corrected by: 06/05/2009

Elevator Name: ELEVATOR # 1

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Ken Swain / 828-350-7000

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ASH CITY SCHOOLS
PO BOX 7347
ASHEVILLE, NC, 28802