



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
9128-24-5997
State Number
10294

EQUIPMENT INSPECTED

State Number: 10294	Type of Unit: Passenger	Floor to Floor: 1 to 4
Capacity: 2500	Manuf: GENERAL	Speed: 100
Landings: 4	Installed: 07/09/1982	Rope Size:
Volts: 208	Complied: 07/09/1982	Entrances: 1

OWNER

72 PATTON ASSOCIATES
72 PATTON AVENUE
ASHEVILLE, NC, 28801

OCCUPANT

72 PATTON ASSOCIATES
72 PATTON AVENUE
ASHEVILLE, NC, 28801

INSPECTION INFORMATION

Inspection Date 05/08/2009	Type Inspection Routine	Certificate Status Re-issued	Inspector 24 - Moore	County BUNCOMBE	11 B
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------	------

VIOLATIONS

- 8.6.1.2.1 Provide a written maintenance program. Place a sign on the controller where the location of the MCP is located and how to access same.
- 2.14.7.4 Protect the car lights from accidental contact. Tubes must be sleeved and have end caps or a solid ceiling. One tube missing sleeve and end caps.

Items must be corrected by: 06/07/2009

Elevator Name: ELEVATOR # 1

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Left with Linda English / 828-252-7381

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

72 PATTON ASSOCIATES
72 PATTON AVENUE
ASHEVILLE, NC, 28801