



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
9135-36-0954
State Number
21192

EQUIPMENT INSPECTED

State Number: 21192	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 2500	Manuf: OTIS	Speed: 150
Landings: 3	Installed: 09/10/2002	Rope Size: 0
Volts: 208	Complied: 09/10/2002	Entrances: 1

OWNER

HOLIDAY INN EXPRESS
149 SPRING FOREST DRIVE
MEBANE, NC, 27302

OCCUPANT

HOLIDAY INN EXPRESS
149 SPRING FOREST DRIVE
MEBANE, NC, 27302

INSPECTION INFORMATION

Inspection Date 05/15/2009	Type Inspection Routine	Certificate Status Re-issued	Inspector 36 - Kirkman	County ALAMANCE
-------------------------------	----------------------------	---------------------------------	---------------------------	--------------------

1

VIOLATIONS

- 8.6.4.8.4 Take steps to keep the machine room access door closed and locked at all times.
8.6.4.8.2 Remove all materials from machine room (machinery space) not pertaining to the maintenance or operation of the elevator(s).

Items must be corrected by: 06/14/2009

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: office

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

HOLIDAY INN EXPRESS
149 SPRING FOREST DRIVE
MEBANE, NC, 27302