N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
9138-46-5255
State Number
5938

EQUIPMENT INSPECTED

State Number: **5938**
Capacity: 2000
Landings: 6
Volts: 208

Type of Unit: Passenger
Manuf: SCHINDLER
Installed: 03/27/1968
Complied: 04/08/1968

Floor to Floor: 1 to 6
Speed: 300
Rope Size: 1/2
Entrances: 1

OWNER
ANTHONY ALLEN PROP. MGR.
PO BOX 10810
RALEIGH, NC, 27605

OCCUPANT
FIRST RALEIGH TELEX
234 FAYETTEVILLE ST
RALEIGH, NC, 27601

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County	
05/18/2009	Routine	Re-issued	46 - Jones	WAKE	92 D

VIOLATIONS

5.1.21.1 Put the in car alarm bell in working order.

Items must be corrected by: 06/17/2009

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: n/a

Inspector _____

THIS IS NOT AN INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:
ANTHONY ALLEN PROP. MGR.
PO BOX 10810
RALEIGH, NC, 27605