N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
9139-48-1447
State Number
17013

EQUIPMENT INSPECTED

State Number: **17013**
Capacity: 2500
Landings: 4
Volts: 480

Type of Unit: Passenger
Manuf: THYSSEN KRUPP
Installed: 11/24/1997
Complied: 01/09/1998

Floor to Floor: 1 to 4
Speed: 150
Rope Size:
Entrances: 1

OWNER
BENCHMARK MANAGEMENT
C/O JANE WHIELDON
NORTH MYRTLE BEACH, SC, 29597

OCCUPANT
WINDJAMMER CONDO
27 W 2ND ST
OCEAN ISLE, NC, 28469

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County
05/19/2009	Routine	Re-issued	48 - Martin	BRUNSWICK

10

VIOLATIONS

8.6.1.6.3[e] Properly maintain all Control and operating circuits and devices. REPAIR POSITION INDICATOR'S IN CAR AND HOISTWAY.

Items must be corrected by: 06/08/2009

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: UNAVAILABLE

Inspector _____

THIS IS NOT AN INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:
BENCHMARK MANAGEMENT
C/O JANE WHIELDON
NORTH MYRTLE BEACH, SC, 29597