N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
9141-48-4766
State Number
24907

EQUIPMENT INSPECTED

State Number: **24907**	Type of Unit: Passenger	Floor to Floor: 1 to 6
Capacity: 3500	Manuf: OTIS	Speed: 150
Landings: 6	Installed:	Rope Size:
Volts: 208	Complied:	Entrances: 1

OWNER
SEASIDELANDING PARTNERS LLC
7265 SEASHELL LANE
OCEAN ISLE BEACH, NC, 28469

OCCUPANT
SEASIDE LANDING CONDOS
7265 SEASHELL LANE
OCEAN ISLE BEACH, NC, 28469

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County
05/21/2009	Routine	Re-issued	48 - Martin	BRUNSWICK

10

VIOLATIONS

n/a No violations found

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: UNAVAILABLE Inspector _____

THIS IS NOT AN INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:
SEASIDELANDING PARTNERS LLC
7265 SEASHELL LANE
OCEAN ISLE BEACH, NC, 28469