



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
9147-16-3567
State Number
22644

EQUIPMENT INSPECTED

State Number: 22644	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2000	Manuf: THYSSEN KRUPP	Speed: 100
Landings: 2	Installed: 12/02/2004	Rope Size: 0
Volts: 208	Complied: 12/02/2004	Entrances: 1
OWNER	OCCUPANT	
BELHAVEN MISSIONARY BAPTIST	BELHAVEN MISSIONARY BAPTIST	
251 EDWARDS ST.	251 EDWARDS ST.	
BELHAVEN, NC, 27810	BELHAVEN, NC, 27810	

INSPECTION INFORMATION

Inspection Date 05/27/2009	Type Inspection Routine	Certificate Status Re-issued	Inspector 16 - Moore	County BEAUFORT
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------

7

VIOLATIONS

n/a No violations found

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Church Office

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

BELHAVEN MISSIONARY BAPTIST
251 EDWARDS ST.
BELHAVEN, NC, 27810