N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
9147-48-1325
State Number
25843

EQUIPMENT INSPECTED

State Number: **25843**
Capacity: 2100
Landings: 2
Volts: 240

Type of Unit: Passenger
Manuf: SCHINDLER
Installed: 06/06/2008
Complied: 06/06/2008

Floor to Floor: 1 to 2
Speed: 100
Rope Size:
Entrances: 1

OWNER
CITY OF SOUTHPORT
201 E. MOORE STREET
SOUTHPORT, NC, 28461

OCCUPANT
FRANKLIN SQUARE ART GALLERY
130 WEST STREET
SOUTHPORT, NC, 28461

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County
05/27/2009	Routine	Re-issued	48 - Martin	BRUNSWICK

10

VIOLATIONS

8.6.1.2.1 Provide a written maintenance program.

Items must be corrected by: 06/06/2009

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: MANAGEMENT

Inspector _____

THIS IS NOT AN INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:
CITY OF SOUTHPORT
201 E. MOORE STREET
SOUTHPORT, NC, 28461