N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
9148-48-1890
State Number
H402

EQUIPMENT INSPECTED

State Number: **H402**
Capacity: 500
Landings: 2
Volts: 120

Type of Unit: Hand Lift
Manuf: STAIRGLIDE
Installed: 07/01/1991
Complied: 07/01/1991

Floor to Floor: 1 to 2
Speed: 10
Rope Size:
Entrances: 2

OWNER
SOLDIER BAY BAPTIST CHURCH
PO BOX 10
ASH, NC, 28420

OCCUPANT
SOLDIER BAY BAPTIST CHURCH
HWY 130
ASH, NC, 28420

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County	
05/28/2009	Routine	Re-issued	48 - Martin	BRUNSWICK	10

VIOLATIONS

2.26.2.7 Put the pit stop switch in working order. STOP SW. AT OPERATING STATION ON LOWER LEVEL.
2.14.1.4.5 Put the in car stop switch in proper working order.

Items must be corrected by: 06/17/2009

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: PASTOR

Inspector _____

THIS IS NOT AN INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:
SOLDIER BAY BAPTIST CHURCH
PO BOX 10
ASH, NC, 28420