



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
9148-48-3270
State Number
25202

EQUIPMENT INSPECTED

State Number: 25202	Type of Unit: Passenger	Floor to Floor: 1 to 4
Capacity: 3500	Manuf: OTIS	Speed: 125
Landings: 4	Installed: 06/02/2008	Rope Size:
Volts: 208	Complied: 06/02/2008	Entrances: 1
OWNER	OCCUPANT	
LEE DEVELOPMENT	DOLPHIN SHORES BLDG 1	
314 WALNUT STREET	2252 BOONESNECK DR.	
WILMINGTON, NC, 28401	SUPPLY, NC, 28462	

INSPECTION INFORMATION

Inspection Date 05/28/2009	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

10

VIOLATIONS

8.6.4.8.1	Clean the elevator machine room.
8.6.4.7.4	Remove the oil from the pit floor.

Items must be corrected by: 06/07/2009

Elevator Name: # 1

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: UNAVAILABLE

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

LEE DEVELOPMENT
314 WALNUT STREET
WILMINGTON, NC, 28401