



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
9152-48-3313
State Number
26304

EQUIPMENT INSPECTED

State Number: 26304	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 2100	Manuf: TKE	Speed: 135
Landings: 3	Installed: 09/09/2008	Rope Size:
Volts: 208	Complied: 09/09/2008	Entrances: 1
OWNER	OCCUPANT	
STATION DEVELOPMENT CORP.	SOUTH HARBOR STATION	
5001 UNIT J O'QUINN BLVD.	4136 VANESSA DRIVE	
SOUTHPORT,NC, NC, 28461	OAK ISLAND, NC, 28465	

INSPECTION INFORMATION

Inspection Date 06/01/2009	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

10

VIOLATIONS

5.1.21.1	Put the in car alarm bell in working order.
8.6.8.9	Signs. Caution signs shall be provided. Damaged or missing signs shall be replaced. 1ST. FL.

Items must be corrected by: 06/21/2009

Elevator Name: # 3

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: UNAVAILABLE

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

STATION DEVELOPMENT CORP.
5001 UNIT J O'QUINN BLVD.
SOUTHPORT,NC, NC, 28461