



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
9152-48-5383
State Number
24780

EQUIPMENT INSPECTED

| | | |
|----------------------------|-------------------------|------------------------|
| State Number: 24780 | Type of Unit: Passenger | Floor to Floor: 1 to 3 |
| Capacity: 2100 | Manuf: TKE | Speed: 135 |
| Landings: 3 | Installed: 06/27/2007 | Rope Size: |
| Volts: 208 | Complied: 06/27/2007 | Entrances: 1 |

OWNER
STATION DEVELOPMENT CORP.
5001 UNIT J O'QUINN BLVD.
SOUTHPORT, NC, NC, 28461

OCCUPANT
SOUTH HARBOR
4132 VANESSA DRIVE
OAK ISLAND, NC, 28429

INSPECTION INFORMATION

| | | | | |
|-------------------------------|----------------------------|---------------------------------|--------------------------|---------------------|
| Inspection Date 06/01/2009 | Type Inspection Routine | Certificate Status Re-issued | Inspector 48 - Martin | County BRUNSWICK |
|-------------------------------|----------------------------|---------------------------------|--------------------------|---------------------|

10

VIOLATIONS

8.6.8.9 Signs. Caution signs shall be provided. Damaged or missing signs shall be replaced. 1ST., 2ND. & 3RD. FLS.
8.6.4.15 Emergency operation of signaling devices, lighting, communication, and ventilation, shall be maintained. EMER. PHONE INOPERATIVE

Items must be corrected by: 06/21/2009

Elevator Name: # 2

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: UNAVAILABLE

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

STATION DEVELOPMENT CORP.
5001 UNIT J O'QUINN BLVD.
SOUTHPORT, NC, NC, 28461