



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**9159-4-2516**  
State Number  
**23277**

EQUIPMENT INSPECTED

State Number: <b>23277</b>	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2100	Manuf: THYSSEN KRUPP	Speed: 80
Landings: 2	Installed: 07/28/2005	Rope Size: 0
Volts: 208	Complied: 02/16/2006	Entrances: 1
OWNER	OCCUPANT	
ELK RIVER COUNTRY CLUB	ELK RIVER CLUB HOUSE	
P.O.BOX 1238	235 CLUB HOUSE DRIVE	
BANNER ELK, NC, 28604	BANNER ELK, NC, 28604	

INSPECTION INFORMATION

Inspection Date 06/08/2009	Type Inspection Routine	Certificate Status Re-issued	Inspector 4 - Henegar	County AVERY
-------------------------------	----------------------------	---------------------------------	--------------------------	-----------------

6

VIOLATIONS

n/a No violations found

Elevator Name: # 2

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Toni Cook # 828-896-9773

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ELK RIVER COUNTRY CLUB  
P.O.BOX 1238  
BANNER ELK, NC, 28604