



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
9159-4-2955
State Number
8962

EQUIPMENT INSPECTED

State Number: **8962**

Capacity: 2000

Landings: 2

Volts: 220

OWNER

ESEECOLA LODGE

P.O BOX 99

LINVILLE, NC, 28646

Type of Unit: Passenger

Manuf: THYSSEN KRUPP

Installed: 06/02/1977

Complied: 06/02/1977

OCCUPANT

ESEECOLA LODGE CLUBHOUSE

83 ROSEBORO ROAD

LINVILLE, NC, 28646

Floor to Floor: 1 to 2

Speed: 100

Rope Size: 0

Entrances: 1

INSPECTION INFORMATION

Inspection Date
06/08/2009

Type Inspection
Routine

Certificate Status
Re-issued

Inspector
4 - Henegar

County
AVERY

6

VIOLATIONS

2.7.2.2.1 Provide clear and lighted access to the machine room.

Items must be corrected by: 07/08/2009

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: John Blaeubum # 828-733-4311

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ESEECOLA LODGE
P.O BOX 99
LINVILLE, NC, 28646