

## N C Department of Labor Elevator Bureau 1101 Mail Service Center, Raleigh, NC 27699-1101

## INSPECTION REPORT

IMPORTANT: Always use State Number in any correspondence relating to your equipment www.nclabor.com/elevator.htm 919-707-7927 Report Number 9159-4-5054
State Number 13063

6

		EQUI	PMENT INSPECTED			
State Number: 13063		Type of Unit: Freight		Floor to Floor: 1 to 3		
Capacity: 2000		Manuf: SOUTHERN		Speed: 115		
Landings: 5		Installed: 05/31/1989		Rope Size: 0		
Volts: 208		Complied: 05/31/1	989	Entrances: 2		
OWNER		OCCUPANT				
ELK RIVER COUNTRY CLUB			ELK RIVER CLUB HOUSE			
P.O. BOX 1238			235 CLUB HOUSE DRIVE			
BANNER ELK, NC, 28604			BANNER ELK, NC, 28604			
		INSPEC	CTION INFORMATION			
Inspection Date 06/08/2009		Type Inspection Routine	Certificate Status Re-issued	Inspector 4 - Henegar	County AVERY	
			VIOLATIONS			
8.6.4.7.1	Take steps to clean the elevator pit.					
5.1.21.1	Take steps to place the in car alarm bell in proper working order.					
8.11.3.2.1	Take steps to perfor	Take steps to perform the annual relief valve test. ( 2nd Notice Comlpy with in 10 Days )				

Items must be corrected by: 06/18/2009 Elevator Name: # 1

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: Toni Cook # 828-896-9773

Inspector

To make changes to the invoice mailing address please call: 919-733-0372

THIS IS NOT AN INVOICE

ELK RIVER COUNTRY CLUB
An invoice will be mailed to: P.O. BOX 1238

BANNER ELK, NC, 28604