N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
9166-36-2561
State Number
14971

EQUIPMENT INSPECTED

State Number: **14971**
Capacity: 4500
Landings: 2
Volts: 460

Type of Unit: Passenger
Manuf: THYSSEN KRUPP
Installed: 11/19/1993
Complied: 12/08/1993

Floor to Floor: 1 to 2
Speed: 125
Rope Size:
Entrances: 1

OWNER
ALAMANCE COUNTY
124 W ELM ST
GRAHAM, NC, 27253

OCCUPANT
CRIMINAL COURTS BLDG
WEST ELM ST
GRAHAM, NC, 27253

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County
06/15/2009	Routine	Re-issued	36 - Kirkman	ALAMANCE

1

VIOLATIONS

2.14.2.1 Repair or replace damaged flooring in the elevator.

Items must be corrected by: 07/15/2009

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: office

Inspector _____

THIS IS NOT AN INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:
ALAMANCE COUNTY
124 W ELM ST
GRAHAM, NC, 27253