



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

### INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**9168-48-5330**  
State Number  
**14615**

### EQUIPMENT INSPECTED

State Number: <b>14615</b>	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2500	Manuf: OTIS	Speed: 125
Landings: 2	Installed: 09/17/1992	Rope Size:
Volts: 480	Complied: 10/01/1992	Entrances: 1
OWNER	OCCUPANT	
SMITHFIELD PACKING	CAROLINA FOOD PROCESSOR	
1911 S. CHURCH ST.	NC HWY. 87S	
SMITHFIELD, VA, 23430	SMITHFIELD, NC, 27577	

### INSPECTION INFORMATION

Inspection Date 06/17/2009	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BLADEN
-------------------------------	----------------------------	---------------------------------	--------------------------	------------------

9

### VIOLATIONS

- 8.6.4.13.1[g] Properly maintain/ replace astragals and resilient members, door space guards, and sight guards, where required. REPLACE CAR GATE ASTRAGAL.
- 8.6.4.13.1[k] Properly maintain door closers, where required. REPAIR MOTOR ROOM DOOR TO CLOSE & LOCK ON ITS OWN.
- 2.11.3.1 Adjust the elevator hoistway doors to self close fully. 2ND. FL. DOOR STICKING 4" FROM CLOSE.
- 2.27.1.1.2 Put the in car emergency telephone in proper working order.

Items must be corrected by: 07/17/2009

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: HARLAN HUNT

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

SMITHFIELD PACKING  
1911 S. CHURCH ST.  
SMITHFIELD, VA, 23430