



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
9168-8-3249
State Number
17595

EQUIPMENT INSPECTED

State Number: 17595	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2100	Manuf: THYSSEN KRUPP	Speed: 95
Landings: 2	Installed: 07/10/1998	Rope Size:
Volts: 480	Complied: 07/16/1998	Entrances: 1
OWNER	OCCUPANT	
SOUTH PIEDMONT COMMUNITY COLLEGE	SOUTH PIEDMONT COMMUNITY COLLEGE	
PO BOX 126	129 LEDBETTER ST	
POLKTON, NC, 28135	POLKTON, NC, 28135	

INSPECTION INFORMATION

Inspection Date 06/17/2009	Type Inspection Routine	Certificate Status Re-issued	Inspector 8 - Burris	County ANSON
-------------------------------	----------------------------	---------------------------------	-------------------------	-----------------

4

VIOLATIONS

NONE

Elevator Name: MARTIN BLDG

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: REP- MIKE NAPIER

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

SOUTH PIEDMONT COMMUNITY COLLEGE
PO BOX 126
POLKTON, NC, 28135