



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**9175-36-5886**  
State Number  
**N1.50**

EQUIPMENT INSPECTED

State Number: <b>N1.50</b>	Type of Unit: Freight	Floor to Floor: 1 to 3
Capacity: 1500	Manuf: PARK	Speed: 50
Landings: 3	Installed: 06/11/1924	Rope Size: 5/8
Volts: 220	Complied: 06/11/1924	Entrances: 2
OWNER	OCCUPANT	
ROBERT L NANCE 336- 516-5482	JULIAN M. DOBY ATTORNET AT LAW	
PO BOX 788	200 MAIN ST	
BURLINGTON, NC, 27216	GRAHAM, NC, 27253	

INSPECTION INFORMATION

Inspection Date 06/24/2009	Type Inspection Routine	Certificate Status Re-issued	Inspector 36 - Kirkman	County ALAMANCE
-------------------------------	----------------------------	---------------------------------	---------------------------	--------------------

1

VIOLATIONS

8.11.2.2.2 Perform the annual no load safety test

Items must be corrected by: 07/24/2009

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: office

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ROBERT L NANCE 336- 516-5482  
PO BOX 788  
BURLINGTON, NC, 27216