



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
9175-8-3944
State Number
11583

EQUIPMENT INSPECTED

State Number: 11583	Type of Unit: Passenger	Floor to Floor: B to 3
Capacity: 2100	Manuf: SOUTHERN	Speed: 85
Landings: 3	Installed: 01/07/1986	Rope Size:
Volts: 208	Complied: 01/07/1986	Entrances: 1

OWNER

ALVIN NANCE
2903 HOPEWELL CH RD
PEACHLAND, NC, 28133

OCCUPANT

WATSON OFFICE BLDG
201 W MORGAN ST
WADESBORO, NC, 28170

INSPECTION INFORMATION

Inspection Date 06/24/2009	Type Inspection Condemned	Certificate Status Not Issued	Inspector 8 - Burris	County ANSON
-------------------------------	------------------------------	----------------------------------	-------------------------	-----------------

4

VIOLATIONS

NCAC	UNIT OUT OF SERVICE MORE THAN 1 YEAR
NCAC	UNIT CONDEMMED
NCAC	PROPERLY LAND ELEVATOR

Items must be corrected by: 07/24/2009

Elevator Name: PASSENGER ELEV

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: REP- ALVIN NANCE

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ALVIN NANCE
2903 HOPEWELL CH RD
PEACHLAND, NC, 28133