



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
9182-16-3198
State Number
24436

EQUIPMENT INSPECTED

State Number: 24436	Type of Unit: Passenger	Floor to Floor: P to 3
Capacity: 2500	Manuf: TKE	Speed: 125
Landings: 4	Installed: 01/09/2007	Rope Size: 0
Volts: 230	Complied: 01/09/2007	Entrances: 2

OWNER

DIXON & MEEKINS
103 EAST 8TH ST
NAGS HEAD, NC, 27959

OCCUPANT

DAY BEACON
326 E. WATER STREET
BELLHAVEN, NC, 27810

INSPECTION INFORMATION

Inspection Date 07/01/2009	Type Inspection Routine	Certificate Status Re-issued	Inspector 16 - Moore	County BEAUFORT
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------

7

VIOLATIONS

- 2.27.3.1 Put the Phase I fire service feature in proper working order. And Push button on 1st floor
- 2.2.5.1 Put the pit lights in proper working order.
- 8.6.4.8.2 Remove all materials from machine room (machinery space) not pertaining to the maintenance or operation of the elevator(s).

Items must be corrected by: 07/31/2009

Elevator Name: A

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Maintenance/ Grounds Keeper, David

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

DIXON & MEEKINS
103 EAST 8TH ST
NAGS HEAD, NC, 27959