



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

### INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**9182-16-5088**  
State Number  
**24437**

#### EQUIPMENT INSPECTED

State Number: <b>24437</b>	Type of Unit: Passenger	Floor to Floor: P to 3
Capacity: 2500	Manuf: TKE	Speed: 125
Landings: 4	Installed: 01/09/2007	Rope Size: 0
Volts: 230	Complied: 01/09/2007	Entrances: 2

#### OWNER

DIXON & MEEKINS  
103 EAST 8TH ST  
NAGS HEAD, NC, 27959

#### OCCUPANT

DAY BEACON  
326 E. WATER STREET  
BELLHAVEN, NC, 27810

#### INSPECTION INFORMATION

Inspection Date 07/01/2009	Type Inspection Routine	Certificate Status Re-issued	Inspector 16 - Moore	County BEAUFORT
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------

7

#### VIOLATIONS

- 8.6.1.6.5 Provide the required fire extinguisher in the machine room.
- 8.6.4.8.2 Remove all materials from machine room (machinery space) not pertaining to the maintenance or operation of the elevator(s).

Items must be corrected by: 07/31/2009

Elevator Name: B

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Maintenance /Grounds Keeper

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

DIXON & MEEKINS  
103 EAST 8TH ST  
NAGS HEAD, NC, 27959