

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-807-2770

Report Number 9189-48-278 State Number 7057
--

EQUIPMENT INSPECTED

State Number: 7057	Type of Unit: Passenger	Floor to Floor: 1 to 5
Capacity: 4000	Manuf: THYSSEN KRUPP	Speed: 100
Landings: 5	Installed: 07/02/1974	Rope Size: 5/8
Volts: 480	Complied: 08/19/1992	Entrances: 1
OWNER	OCCUPANT	
PROGRESS ENERGY	PROGRESS ENERGY - REACTOR #2	
8470 RIVER ROAD SE	8470 RIVER ROAD SE	
SOUTHPORT, NC, 28461	SOUTHPORT, NC, 28461	

INSPECTION INFORMATION

Inspection Date 07/08/2009	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

10

VIOLATIONS

n/a No violations found

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: RUSSELL TYLER

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

PROGRESS ENERGY
8470 RIVER ROAD SE
SOUTHPORT, NC, 28461