



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
9191-36-1261
State Number
19724

EQUIPMENT INSPECTED

State Number: 19724	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 2100	Manuf: MIM ELE	Speed: 100
Landings: 3	Installed: 03/14/2001	Rope Size:
Volts: 208	Complied: 03/27/2001	Entrances: 1

OWNER

ROBERT NANCE
PO BOX 788
BURLINGTON, NC, 27216

OCCUPANT

MONTWHITE BLDG
200B N MAIN ST
GRAHAM, NC, 27253

INSPECTION INFORMATION

Inspection Date 07/10/2009	Type Inspection Routine	Certificate Status Re-issued	Inspector 36 - Kirkman	County ALAMANCE
-------------------------------	----------------------------	---------------------------------	---------------------------	--------------------

1

VIOLATIONS

- 8.6.10.1 Provide an updated monthly fire service log indicating proper Phase 1 and 2 operation and make available upon request the authority having jurisdiction.
- 8.11.2.2.2 Perform the annual no load safety test

Items must be corrected by: 08/09/2009

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: office

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ROBERT NANCE
PO BOX 788
BURLINGTON, NC, 27216