

N C Department of Labor Elevator Bureau 1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in any correspondence relating to your equipment www.nclabor.com/elevator.htm 919-707-7927 Report Number 9196-24-3060 State Number 20804

EQUIPMENT INSPECTED							
State Number: 20804		Type of Unit	Type of Unit: Passenger		Floor to Floor: 1 to 3		
Capacity:	2500	Manuf: SCI	Manuf: SCHINDLER		Speed: 150		
Landings: 3 Volts: 208 OWNER EQUITY INNS 7700 WOLF RIVER BLVD		Installed: 03	Installed: 03/21/2002 Complied: 05/02/2002		Rope Size: Entrances: 1		
		Complied: (
			OCCUPANT				
			SPRINGHILL SUITES HOTEL 2 BUCKSTONE PLACE				
GERMAN	NTOWN, TN, 38138		ASHEVILLE, NC.	, 28805			
			INSPECTION INFORMATION				
Inspection Date 07/15/2009		Type Inspection Routine	Certificate Status Re-issued	Inspector 24 - Moore	County BUNCOMBE	11 B	
			VIOLATIONS				
8.6.1.6.1	No person shall a safety device!!!!!	t any time make inoperative or ine	ffective any safety device or elec	trical component. The doc	or restrictor that is zip-tyed	open is a	
8 6 4 13 1	•	door restrictors, where required.					
2.27.7.1		re service instructions at the recal	l landing				
8.6.1.2.1							
8.6.4.16		s (floor levels) Car runs do	wn too fast				
Items n	nust be corrected by:	08/14/2009	Elev	Elevator Name: ELEVATOR # 1			
	Elevator Bureau in we with current codes	riting on Corrected Violations For	rm when the following correction	s have been made in order	to bring your equipment in	ıto	
Violations p		Foster / 828-253-4666		Inspector			
THIS IS NOT AN INVOICE			To make changes to the invoice mailing address please call: 919-733-0372				
		An invoice will be mailed to: EQUITY INNS 7700 WOLF RIVER BLVD GERMANTOWN, TN, 38138					