



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
9196-24-5839
State Number
21597

EQUIPMENT INSPECTED

State Number: 21597	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2500	Manuf: ASHEVILLE	Speed: 95
Landings: 2	Installed: 08/14/2003	Rope Size: 0
Volts: 480	Complied: 08/14/2003	Entrances: 1

OWNER

ASHEVILLE CHRISTIAN ACADEMY
PO BOX 1089
SWANNANOVA, NC, 28778

OCCUPANT

ASHEVILLE CHRISTIAN ACADEMY
74 RIVERWOOD ROAD
SWANNANOVA, NC, 28778

INSPECTION INFORMATION

Inspection Date 07/15/2009	Type Inspection Routine	Certificate Status Re-issued	Inspector 24 - Moore	County BUNCOMBE	11 B
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------	------

VIOLATIONS

8.6.1.2.1	Provide a written maintenance program. Locate a sign on the controller for location and access.
8.6.4.13.1[1]	Properly maintain door restrictors, where required.

Items must be corrected by: 08/14/2009

Elevator Name: ELEVATOR EAST

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Mark Brant / 828-581-2200

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ASHEVILLE CHRISTIAN ACADEMY
PO BOX 1089
SWANNANOVA, NC, 28778