N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
9196-36-0793
State Number
22750

EQUIPMENT INSPECTED

State Number: **22750**
Capacity: 2100
Landings: 3
Volts: 208

Type of Unit: Passenger
Manuf: THYSSEN KRUPP
Installed: 04/07/2005
Complied: 04/07/2005

Floor to Floor: 1 to 3
Speed: 100
Rope Size:
Entrances: 1

OWNER
ALAMANCE COUNTRY CLUB
2402 PINEWAY DRIVE
BURLINGTON, NC, 27215

OCCUPANT
ALAMANCE COUNTRY CLUB
2402 PINEWAY DRIVE
BURLINGTON, NC, 27215

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County
07/15/2009	Routine	Re-issued	36 - Kirkman	ALAMANCE

1

VIOLATIONS

NONE FOUND AT TIME OF INSPECTION

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: office

Inspector _____

THIS IS NOT AN INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:
ALAMANCE COUNTRY CLUB
2402 PINEWAY DRIVE
BURLINGTON, NC, 27215