



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
9197-7-0477
State Number
19556

EQUIPMENT INSPECTED

State Number: 19556	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 3500	Manuf: THYSSEN KRUPP	Speed: 100
Landings: 2	Installed: 12/21/2000	Rope Size:
Volts: 480	Complied: 12/21/2000	Entrances: 1
OWNER	OCCUPANT	
ASHE CO COMMISSIONERS	ASHE CO AGRICULTURE OFFICE	
150 GOV'T CIRCLE STE 2500	134 GOV'T CIRCLE	
JEFFERSON, NC, 28640	JEFFERSON, NC, 28640	

INSPECTION INFORMATION

Inspection Date 07/16/2009	Type Inspection Routine	Certificate Status Re-issued	Inspector 7 - Hoffman	County ASHE
-------------------------------	----------------------------	---------------------------------	--------------------------	----------------

5

VIOLATIONS

n/a No violations found

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: BARRY WOODIE 336-846-5880

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ASHE CO COMMISSIONERS
150 GOV'T CIRCLE STE 2500
JEFFERSON, NC, 28640