N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
9201-12-1818
State Number
20246

EQUIPMENT INSPECTED

State Number: **20246**
Capacity: 5000
Landings: 4
Volts: 480

Type of Unit: Passenger
Manuf: THYSSEN KRUPP
Installed: 03/14/2002
Complied: 03/14/2002

Floor to Floor: 1 to 4
Speed: 150
Rope Size:
Entrances: 1

OWNER
RANDOLPH COUNTY
2212 S FAYETTEVILLE ST
ASHEBORO, NC, 27205

OCCUPANT
RANDOLPH COUNTY COURT HOUSE
SALISBURY ST
ASHEBORO, NC, 27203

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County
07/20/2009	Routine	Re-issued	12 - Essick	RANDOLPH

76

VIOLATIONS

8.6 Make restrictor function

Items must be corrected by: 08/19/2009

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: Karen, Maintenance

Inspector _____

THIS IS NOT AN INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:
RANDOLPH COUNTY
2212 S FAYETTEVILLE ST
ASHEBORO, NC, 27205