



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**9204-12-3261**  
State Number  
**12327**

EQUIPMENT INSPECTED

State Number: <b>12327</b>	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 2500	Manuf: THYSSEN KRUPP	Speed: 100
Landings: 3	Installed: 11/12/1987	Rope Size:
Volts: 208	Complied: 12/08/1987	Entrances: 1
OWNER	OCCUPANT	
RANDOLPH HOSPITAL	RANDOLPH HOSPITAL	
PO BOX 1048	364 WHITE OAK ST	
ASHEBORO, NC, 27204	ASHEBORO, NC, 27203	

INSPECTION INFORMATION

Inspection Date 07/23/2009	Type Inspection Routine	Certificate Status Re-issued	Inspector 12 - Essick	County RANDOLPH
-------------------------------	----------------------------	---------------------------------	--------------------------	--------------------

76

VIOLATIONS

3.7 Missing ABC fire extinguisher in wquipment room

Items must be corrected by: 08/22/2009

Elevator Name: 1

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: Maintenance

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

RANDOLPH HOSPITAL  
PO BOX 1048  
ASHEBORO, NC, 27204