



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
9204-12-3414
State Number
25740

EQUIPMENT INSPECTED

State Number: 25740	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 5000	Manuf: TKE	Speed: 175
Landings: 2	Installed:	Rope Size:
Volts: 480	Complied:	Entrances: 2
OWNER	OCCUPANT	
RANDOLPH HOSPITAL	RANDOLPH HOSPITAL	
364 WHITE OAK ST	364 WHITE OAK ST	
ASHEBORO, NC, 27204	ASHEBORO, NC, 27204	

INSPECTION INFORMATION

Inspection Date 07/23/2009	Type Inspection Routine	Certificate Status Re-issued	Inspector 12 - Essick	County RANDOLPH
-------------------------------	----------------------------	---------------------------------	--------------------------	--------------------

76

VIOLATIONS

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Maintenance

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

RANDOLPH HOSPITAL
364 WHITE OAK ST
ASHEBORO, NC, 27204