



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
9209-48-0024
State Number
24924

EQUIPMENT INSPECTED

State Number: 24924	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity:	Manuf: OTIS	Speed: 100
Landings: 2	Installed: 08/23/2007	Rope Size:
Volts: 208	Complied: 08/23/2007	Entrances: 1
OWNER	OCCUPANT	
KAMRAN GOUDARZI	SHALLOTTE URGENT CARE	
1721 MEDICAL PARK DR	4501 MAIN ST	
WILMINGTON, NC, 28403	SHALLOTTE, NC, 28459	

INSPECTION INFORMATION

Inspection Date 07/28/2009	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

10

VIOLATIONS

2.24	Drive machine. CAR ON 1ST. FL. MOTOR RUNS NON STOP UNTIL MAIN LINE RESET.
2.2.5.1	Put the pit lights in proper working order.
2.14.7.1.4	Put the car top light in working order.
8.6.4.8.1	Clean the machine room (machinery space) of all debris.

Items must be corrected by: 08/17/2009

Elevator Name: # 1

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: MANAGEMENT

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

KAMRAN GOUDARZI
1721 MEDICAL PARK DR
WILMINGTON, NC, 28403