



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
9219-48-2212
State Number
15684

EQUIPMENT INSPECTED

State Number: 15684	Type of Unit: Passenger	Floor to Floor: G to 2
Capacity: 2100	Manuf: OTIS	Speed: 125
Landings: 3	Installed: 10/30/1995	Rope Size:
Volts: 208	Complied: 10/30/1995	Entrances: 1
OWNER	OCCUPANT	
CASWLL PARTNERSHIP	OCEAN GREENS BLDG #2	
OCEAN GREENS LANE	55-58 FOX FIRE LN.	
CASWELL BEACH, NC, 28465	CASWELL BEACH, NC, 28465	

INSPECTION INFORMATION

Inspection Date 08/07/2009	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

10

VIOLATIONS

8.6.4.7.1 Clean the elevator pit.

Items must be corrected by: 08/27/2009

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: UNAVAILABLE

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

CASWLL PARTNERSHIP
OCEAN GREENS LANE
CASWELL BEACH, NC, 28465