



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
9223-48-4513
State Number
26886

EQUIPMENT INSPECTED

State Number: 26886	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2500	Manuf: TKE	Speed: 150
Landings: 2	Installed: 08/11/2009	Rope Size:
Volts: 480	Complied:	Entrances: 1
OWNER	OCCUPANT	
BORDEAUX CONSTRUCTION CO	BRUNSWICK COUNTY DEPT OF SOCIAL SERVICES	
100 E BRITANIA AVENUE	60 GOVERNMENT CTR DR NE	
DURHAM, NC, 27704	BOLIVIA, NC, 28422	

INSPECTION INFORMATION

Inspection Date 08/11/2009	Type Inspection New	Certificate Status Not Issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	------------------------	----------------------------------	--------------------------	---------------------

10

VIOLATIONS

1.1 FAILED DUE TO NO EMER. POWER JEWEL ON LOBBY HALL BUTTON STATION & UNABLE TO TEST EMER. BACKUP POWER.

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: BOB [TKE]

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

BORDEAUX CONSTRUCTION CO
100 E BRITANIA AVENUE
DURHAM, NC, 27704