N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
9229-16-1493
State Number
25683

EQUIPMENT INSPECTED

State Number: **25683**
Capacity: 2500
Landings: 4
Volts: 208

Type of Unit: Passenger
Manuf: OTIS
Installed: 07/31/2008
Complied: 07/31/2008

Floor to Floor: 1 to 4
Speed: 100
Rope Size: 0
Entrances: 1

OWNER
PROGRESS COMPANIES
104 N MARKET STREET
WASHINGTON, NC, 27889

OCCUPANT
MOSS LANDING
235 E WATER STREET
WASHINGTON, NC, 27889

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County
08/17/2009	Routine	Re-issued	16 - Moore	BEAUFORT

7

VIOLATIONS

8.6.1.6.5 Provide the required fire extinguisher in the machine room.

Items must be corrected by: 09/16/2009

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: Stan with Progress Companies

Inspector _____

THIS IS NOT AN INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:
PROGRESS COMPANIES
104 N MARKET STREET
WASHINGTON, NC, 27889